

Date : 08/03/2021
Project No : 2020C002
Client Company : Toll Bros. Inc.
Arrival Time : 08/03/2021 09:00
Onsite Hours : 02:00

ASEC Report ID : 32891
Name of the Project : Northfields at Polo Fields
Project Location : 4805 Pittman Road, Forsyth County, Georgia
Weather : sunny
Departure Time : 08/03/2021 11:00
ASEC Technician Name : Russell Hendrix

The site was visited by the undersigned AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to assure compliance with project drawings/specifications, applicable codes, and materials submittals. The following tests were made on site today:

A DCP test was conducted for Lot #17. The building site was flat with a small amount of gravel on the surface. Please find the attached results.

A DCP was conducted on Lot #15. A large area of this lot was blocked by debris not yet removed by the grading company. Several off sets were required for the back of lot as flecks of rock caused Auger refusal.

A DCP test was conducted for Lot # 11. An area of this lot was was Blocked as a gravel storage area. After several Off sets test data was recorded.



Ramchandra R. Mogulla
GA P.E. 036021
Senior Engineer

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.