

Date : 09/14/2021
Project No : 2021C061
Client Company : Pulte Group
Arrival Time : 09/14/2021 14:00
Onsite Hours : 04:00

ASEC Report ID : 33839
Name of the Project : Brighton
Project Location : 1148 Forrest Ave, Fayetteville, GA 30214
Weather : Partly cloudy
Departure Time : 09/14/2021 18:00
ASEC Technician Name : Christopher Burrow II

An ASEC technician was present at the above mentioned site for the purpose of DCP bearing pressure tests. During testing it was noted that lot 23 is unsuitable for concrete due to soil that is non compliant with the allowable bearing pressure. Plans for future testing to determine the extent of unsuitable soil have been discussed with the contractor.



Ramchandra R. Mogulla
GA P.E. 036021
Senior Engineer

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.