

Date : 12/02/2021
Project No : 2021C061
Client Company : Pulte Group
Arrival Time : 11/30/2021 03:00
Onsite Hours : 01:30

ASEC Report ID : 34676
Name of the Project : Brighton
Project Location : 1148 Forrest Ave, Fayetteville, GA 30214
Weather : sunny
Departure Time : 11/30/2021 04:30
ASEC Technician Name : Russell Hendrix

The site was visited by the undersigned AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to assure compliance with project drawings/specifications, applicable codes, and materials submittals. The following observations were made on Lot #28 Brighton today:

Upon visual inspection it was requested that all organic material (leaves) and debris be removed from footing and slab areas before concrete placement. Upon probing and DCP testing the footing was deemed suitable for concrete placement.

DCP TEST DATA SHEET

Project Name: Brighton **Date:** 11/30/21
Project Number: Lot 28 **Technician:** Russ Hendrix
Project Location:

DCP LOCATION:
Lot #,
North/South/Center
etc

Footing

DCP LOCATION:
Lot #,
North/South/Center
etc

Depth (feet)	Set 2"	N 1.75"	Description	Depth (feet)	Set 2"	N 1.75"	Description
1		20	Red silty fine sand				
2		16	Red silty fine sand				
3		14	Red silty fine sand				
4		14	Red silty fine sand				


Kenneth Mosman

Date : 12/02/2021
Project No : 2021C061
Client Company : Pulte Group
Arrival Time : 11/30/2021 03:00
Onsite Hours : 01:30

ASEC Report ID : 34676
Name of the Project : Brighton
Project Location : 1148 Forrest Ave, Fayetteville, GA 30214
Weather : sunny
Departure Time : 11/30/2021 04:30
ASEC Technician Name : Russell Hendrix

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.