

Date : 12/17/2021
Project No : 2021C061
Client Company : Pulte Group
Arrival Time : 12/19/2021 09:00
Onsite Hours : 05:00

ASEC Report ID : 52031
Name of the Project : Brighton
Project Location : 1148 Forrest Ave, Fayetteville, GA 30214
Weather : cloudy
Departure Time : 12/19/2021 14:00
ASEC Technician Name : Vidal Dias

The site was visited by the undersigned AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services for Lot #19. Visual observation techniques were employed to assure compliance with project drawings/specifications, applicable codes, and materials submittals. The following observations were made on-site today:

The footing evaluation was performed by visual inspection, hand probing, and dynamic cone penetrometer (DCP) testing. DCP 's were performed on the north and east sides of the lot. During the evaluation, well-compacted fill soils were encountered underlain by residual soils. Lot #19 is suitable for concrete placement.


Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.