

Date : 12/21/2021
Project No : 2021C060
Client Company : Pulte Group
Arrival Time : 12/06/2021 15:00
Onsite Hours : 01:00

ASEC Report ID : 52813
Name of the Project : Suncity - Peachtree
Project Location : Griffin, GA
Weather : cloudy
Departure Time : 12/06/2021 16:00
ASEC Technician Name : Russell Hendrix

The site was visited by the undersigned AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to assure compliance with project drawings/specifications, applicable codes, and materials submittals. The following observations were made on site today:

A request was made to inspect Lot #101 in the "Passport" section of the development. All rebar was installed to IBC code for size, spacing and quantity. The area was probed and a DCP was completed. The foundation bearing pressure was found to be suitable for concrete placement. Please see the attached report.

DCP TEST DATA SHEET

Project Name:	Suncity	Date:	12/06/21
Project Number:	2021c060	Technician:	Russ Hendrix
Project Location:			Griffin

DCP LOCATION:		DCP LOCATION:	
Lot #,	Lot 101	Lot #,	
North/South/Center etc		North/South/Center etc	

Depth (feet)	Set 2"	N 1.75"	Description	Depth (feet)	Set 2"	N 1.75"	Description
1		10	Red silty fine sand	1			
2		12	Red silty fine sand	2			
3		10	Red silty fine sand	3			
4		10	Red silty fine sand	4			
5				5			
6				6			
7				7			

Date : 12/21/2021
Project No : 2021C060
Client Company : Pulte Group
Arrival Time : 12/06/2021 15:00
Onsite Hours : 01:00

ASEC Report ID : 52813
Name of the Project : Suncity - Peachtree
Project Location : Griffin, GA
Weather : cloudy
Departure Time : 12/06/2021 16:00
ASEC Technician Name : Russell Hendrix

8	8
9	9
10	10

DCP LOCATION:
Lot #,
North/South/Cente
r etc

DCP LOCATION:
Lot #,
North/South/Cente
r etc

Depth (feet)	Set 2"	N 1.75"	Description	Depth (feet)	Set 2"	N 1.75"	Description
1				1			
2				2			
3				3			
4				4			
5				5			
6				6			
7				7			
8				8			
9				9			
10				10			

NOTES:


Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without

Date : 12/21/2021
Project No : 2021C060
Client Company : Pulte Group
Arrival Time : 12/06/2021 15:00
Onsite Hours : 01:00

Daily Field Report

ASEC Report ID : 52813
Name of the Project : Suncity - Peachtree
Project Location : Griffin, GA
Weather : cloudy
Departure Time : 12/06/2021 16:00
ASEC Technician Name : Russell Hendrix

written approval from AS Engineering and Consulting LLC.