

Date : 01/07/2022
 Project No : 2021C060
 Client Company : Pulte Group
 Arrival Time : 01/07/2022 12:00
 Onsite Hours : 02:00

ASEC Report ID : 52898
 Name of the Project : Suncity - Peachtree
 Project Location : Griffin, GA
 Weather : sunny
 Departure Time : 01/07/2022 14:00
 ASEC Technician Name : Russell Hendrix

The site was visited by the undersigned AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to assure compliance with project drawings/specifications, applicable codes, and materials submittals. The following observations were made on site today:

A footing/slab inspection was conducted using Dynamic Cone Penetrometer (DCP) equipment for Lot #111, Pod 13 in the "Passport" section of Suncity in Griffin, GA. The footings were found to be suitable for a soil bearing pressure of 2000 psf. DCP results are in the attached table.

DCP TEST DATA SHEET

Project Name: Suncity **Date:** 01/07/22
Project Number: 2021C060 **Technician:** Russ Hendrix
Project Location: Griffin, GA Pod 13, Lot 111

DCP LOCATION:
Lot #111, footing, Test #1
North/South/Center etc

DCP LOCATION:
Lot #, Footing Test #2
North/South/Center etc

Depth (feet)	Set 2"	N 1.75"	Description	Depth (feet)	Set 2"	N 1.75"	Description
1		15	Red fine sandy silt	1		AR	Red fine silty sand with stone mix
2		10	Red fine sandy silt	2			
3		AR	Red fine sandy silt/stone mix	3			
4				4			
5				5			
6				6			
7				7			

Date : 01/07/2022
 Project No : 2021C060
 Client Company : Pulte Group
 Arrival Time : 01/07/2022 12:00
 Onsite Hours : 02:00

ASEC Report ID : 52898
 Name of the Project : Suncity - Peachtree
 Project Location : Griffin, GA
 Weather : sunny
 Departure Time : 01/07/2022 14:00
 ASEC Technician Name : Russell Hendrix

8	8
9	9
10	10

DCP LOCATION:		DCP LOCATION:
Lot #,	Footing Test #3	Lot #,
North/South/Center etc		North/South/Center etc

Depth (feet)	Set 2"	N 1.75"	Description	Description
1		9	Red fine sandy silt	
2		12	Red fine sandy silt	
3		13	Red fine sandy silt	
4	AR		Red fine sandy silt w stone mix	4
5				5
6				6
7				7
8				8
9				9
10				10

NOTES:

Date : 01/07/2022
Project No : 2021C060
Client Company : Pulte Group
Arrival Time : 01/07/2022 12:00
Onsite Hours : 02:00

ASEC Report ID : 52898
Name of the Project : Suncity - Peachtree
Project Location : Griffin, GA
Weather : sunny
Departure Time : 01/07/2022 14:00
ASEC Technician Name : Russell Hendrix



Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.