

Date : 04/03/2021
Project No : 2020C002
Client Company : Toll Bros. Inc.
Arrival Time : 04/03/2021 09:00
Onsite Hours : 05:00

ASEC Report ID : 7419
Name of the Project : Northfields at Polo Fields
Project Location : 4805 Pittman Road, Forsyth County, Georgia
Weather : Sunny
Departure Time : 04/03/2021 14:00
ASEC Technician Name : Andrew McCullough

The site was visited by the undersigned AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to assure compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were made on site today.

1. The inspector visually observed the installation of the previously recommended soil bridge over lots #2-#3. A single two foot lift was placed to bridge over at the existing grade in the above mentioned area. A dozer was utilized to spread the soil to the desired thickness. No structural fill was placed on top at this time. The bridge was installed per ASEC recommendation. The remainder of the fill that will be placed in this area will be tested for compaction.



Ramchandra R. Mogulla
GA P.E. 036021
Senior Engineer

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.