

Date : 01/16/2021
Project No : 2021C005
Client Company : DR Horton
Arrival Time : 01/16/2021 08:00
Onsite Hours : 06:00

ASEC Report ID : 1545
Name of the Project : Flat Rock Ph 2-Lime Application
Project Location : Evans Mill Road at Browns Mill Road,
Stonecrest, GA
Weather : Sunny
Departure Time : 01/16/2021 14:00
ASEC Technician Name : Dave Bek

The site was visited by the undersigned AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to assure compliance with project drawings/specifications, applicable codes, and materials submittals. The following observations were made on site today:

- Compaction work continued on lot 83. Upon completion two DCP tests were performed to test the resulting compaction. (See DCP test results) The contractor was informed of the test results.
- Fill material was brought from offsite and stock piled between lot 83 - 84. This soil was determined to be the same material as the existing fill stockpiled onsite. (Red Silty Sand)
- A moisture test was performed and showed that this material to be at 19%
- Digging was performed in the eastern most section of lot 84 where fill material had previously been stockpiled. The area was cut down 6 - 7 feet.



Dave Bek

Senior Engineering Technician



Ramchandra R. Mogulla

GA P.E. 036021

Senior Engineer

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.