

Density Test Report

Date : 09/13/2021
Project No : 2020C002
Client Company : Toll Bros. Inc.
Arrival Time : 09/13/2021 01:15
Onsite Hours : 03:00

ASEC Report ID : 33896
Name of the Project : Northfields at Polo Fields
Project Location : 4805 Pittman Road, Forsyth County, Georgia
Weather : sunny
Departure Time : 09/13/2021 04:15
ASEC Technician Name : Russell Hendrix

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
09/13/2021	5	25.4	125.8	P-1	97.7	22.2	102.7	95	D6938	Pass
Location : lot 34, Elv/Depth :1065										
Comment : Please see attached report.										
Tested By : Russell Hendrix Gauge Serial No. : 29588										

Remark: Test performed in general accordance with referenced ASTM Method.



Ramchandra R. Mogulla
GA P.E. 036021
Senior Engineer

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 09/13/2021
Project No : 2020C002
Client Company : Toll Bros. Inc.
Arrival Time : 09/13/2021 01:15
Onsite Hours : 03:00

ASEC Report ID : 33896
Name of the Project : Northfields at Polo Fields
Project Location : 4805 Pittman Road, Forsyth County, Georgia
Weather : sunny
Departure Time : 09/13/2021 04:15
ASEC Technician Name : Russell Hendrix

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
02/26/2021	P-1	97.7	22.2	Standard	Light Brown Silty CLAY