

Date : 07/17/2026
Project No : 2025C214
Client Company : Artisan
Arrival Time : 07/17/2026 08:00
Onsite Hours : 10:30


ASEC Report ID : 96296
Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
Project Location : Dallas
Weather : cloudy
Departure Time : 07/17/2026 18:30
ASEC Technician Name : Clyde Smith

On the above date the writer was onsite as requested and assisted in monitoring testing concrete placement at dead man footing east side wall. One set of (6) 4×8 test cylinders were made for 50 cubic yards pour.

The writer also continued observation of reinforcing steel being installed at bridge slab panels. Recommendations made was move vertical bars off top of nelson stubs in panels for sufficient clearance. Also complete clean up of trash and debris off panels. The writer also observed added #6 bars (vertical) under support plate holding threaded dowel bolts for hanging the sanitary sewer line under bridge.



Monitoring concrete pour and testing at dead man footing wall



Date : 07/17/2026
Project No : 2025C214
Client Company : Artisan
Arrival Time : 07/17/2026 08:00
Onsite Hours : 10:30


ASEC Report ID : 96296
Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
Project Location : Dallas
Weather : cloudy
Departure Time : 07/17/2026 18:30
ASEC Technician Name : Clyde Smith



Observation of reinforcing steel in place at bridge slab panels according to site document in title Bridge Deck,dated 2/20/26.Drawing No. R3.0




Vertical #6 bars added at support bolts for hanging sanitary sewer line



Date : 07/17/2026
Project No : 2025C214
Client Company : Artisan
Arrival Time : 07/17/2026 08:00
Onsite Hours : 10:30

ASEC Report ID : 96296
Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
Project Location : Dallas
Weather : cloudy
Departure Time : 07/17/2026 18:30
ASEC Technician Name : Clyde Smith



The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.