

Date : 07/10/2026
Project No : 2026C101
Client Company : Artisan
Arrival Time : 07/10/2026 10:00
Onsite Hours : 01:00

ASEC Report ID : 96093
Name of the Project : Seven Hills PHASE 13, UNIT 4 Lots
Project Location : Dallas
Weather : sunny
Departure Time : 07/10/2026 11:00
ASEC Technician Name : Samara Simha Reddy Kandi

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

I arrived at the site to perform compaction testing; however, the lot areas were not ready for testing at the time of the visit. Therefore, no density tests were performed.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.