

Date : 06/24/2026
Project No : 2026C122
Client Company : WSP
Arrival Time : 06/24/2026 9:00
Onsite Hours : -8:00

ASEC Report ID : 95992
Name of the Project : Courtesy Pkwy Expansion
Project Location : Conyers
Weather : clear and sunny
Departure Time : 06/24/2026 1:00
ASEC Technician Name : Narayana Ganesh Undavalli

Location(S):

Testing: 2 Set of concrete specimens (4 per set) were cast during the cast-in-place concrete pour at the above referenced location, in accordance with ASTM C31. The specimen will remain on site for the initial 24-48 hrs curing.

Compliance: ☒ Field placement of concrete appeared to be in general accordance with the project specifications (i.e., slump, temperature, etc) (refer to remarks below)
☐ Deviations and/or noncompliances were noted during the field placement (refer to remarks below)

Specimen Pick Up: 2 Sets of concrete specimens/ 4 specimen per set were picked up & transported to AS Engineering and Consulting LLC (ASEC) for curing and testing in accordance with ASTM C39, C670/1231

Field Curing: Specimen were stored for the initial 24 hours
☒ Near the poured structure
☐ In an insulated curing box
☐ Other

Remarks: Class A pour for wall Temp of concrete = 80 amb temp = 75 Slump = 2 air = 2 unit wt of concrete = 142. Class B pour for curb side Temp of concrete = 82 amb temp = 78 slump = 2.5 air = 2.9 unit wt of concrete = 143.

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.