

Date : 06/25/2026
Project No : 2026C125
Client Company : Lewis Contracting
Arrival Time : 06/25/2026 08:00
Onsite Hours : 9:00

ASEC Report ID : 95618
Name of the Project : Pittman Park - Garibaldi St. Stormwater
Project Location : Atlanta
Weather : Sunny
Departure Time : 06/25/2026 17:00
ASEC Technician Name : Sean Willett

Location(S): Footing for retaining wall by entrance of site

Testing: 1 Set of concrete specimens (6 per set) were cast during the cast-in-place concrete pour at the above referenced location, in accordance with ASTM C31. The specimen will remain on site for the initial 24-48 hrs curing.

Compliance: ☒ Field placement of concrete appeared to be in general accordance with the project specifications (i.e., slump, temperature, etc) (refer to remarks below)
☒ Deviations and/or noncompliances were noted during the field placement (refer to remarks below)

Specimen Pick Up: 1 Sets of concrete specimens/ 6 specimen per set were picked up & transported to AS Engineering and Consulting LLC (ASEC) for curing and testing in accordance with ASTM C39, C670/1231

Field Curing: Specimen were stored for the initial 24 hours
☒ Near the poured structure
☐ In an insulated curing box
☐ Other

Remarks:

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 06/25/2026
Project No : 2026C125
Client Company : Lewis Contracting
Arrival Time : 06/25/2026 08:00
Onsite Hours : 9:00

ASEC Report ID : 95618
Name of the Project : Pittman Park - Garibaldi St. Stormwater
Project Location : Atlanta
Weather : Sunny
Departure Time : 06/25/2026 17:00
ASEC Technician Name : Sean Willett

PLACEMENT INFORMATION - Cylinder

Set Number: A	Laboratory Number: 2026-C224
Date Sampled: 06/25/2026	Time Sampled: 16:00
Sampled By: Sean Willett	Concrete Supplier: quickcrete
Contractor: Lewis Contracting	Mix ID: 45000COMNAASHAB
Truck Number: 62382872	Quantity of Load: 27.0
Time Batched: 14:42	Specified Strength: 4500
Location of Placement: Footing for retaining wall by entrance of site	Concrete Temp (°f): 90
Number of Samples Cast: 6	Air Content (%): 1.5
Ambient Temp (°f): 82	Unit Weight (pcf): 146.0
Slump (in.): 7.0	Water Added (gal.): N/A

Specimen Number	Scheduled Test Date	Date Tested	Age (Days)	Dia (in.)	Area (sq in.)	Max Load (lbf)	Strength (psi)	% Design Strength	Fracture Type
1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

UNLESS OTHERWISE SPECIFIED, TESTS WERE PERFORMED IN ACCORDANCE WITH ASTM METHODS C31, C39, C138, C143, C173, C1064.

(1) Cone (2) Cone-split (3) Vertical (4) Shear (5) Edge Fracture (6) Pointed

Kenneth Mosman

Kenneth Mosman