

Date : 06/24/2026
Project No : 2026C136
Client Company : RS Homes
Arrival Time : 06/24/2026 08:00
Onsite Hours : 9:00

ASEC Report ID : 95497
Name of the Project : Collett Farms Storm Line & Pavement
Project Location : Canton
Weather : sunny
Departure Time : 06/24/2026 17:00
ASEC Technician Name : Samara Simha Reddy Kandi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
06/24/2026	1	26.0	99.0	2026-179	98.3	22.8	100.7	100	D6938	Pass
Location : Roadway, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
06/24/2026	2	23.7	99.6	2026-179	98.3	22.8	101.3	100	D6938	Pass
Location : Roadway, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
06/24/2026	3	23.7	99.4	2026-179	98.3	22.8	101.1	100	D6938	Pass
Location : Roadway, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
06/24/2026	4	25.6	98.8	2026-179	98.3	22.8	100.5	100	D6938	Pass
Location : Roadway, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
06/24/2026	5	24.9	98.7	2026-179	98.3	22.8	100.4	100	D6938	Pass
Location : Roadway, Elv/Depth :1 foot below finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										

Remark: Test performed in general accordance with signed referenced ASTM Method.

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 06/24/2026
Project No : 2026C136
Client Company : RS Homes
Arrival Time : 06/24/2026 08:00
Onsite Hours : 9:00

ASEC Report ID : 95497
Name of the Project : Collett Farms Storm Line & Pavement
Project Location : Canton
Weather : sunny
Departure Time : 06/24/2026 17:00
ASEC Technician Name : Samara Simha Reddy Kandi

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
06/18/2026	2026-179	98.3	22.8	Standard	Red sandy silt