

Date : 06/12/2026
Project No : 2026C142
Client Company : KFE
Arrival Time : 06/12/2026 14:00
Onsite Hours : 02:00

ASEC Report ID : 95287
Name of the Project : Bailey Station Way
Project Location : Sharpsburg
Weather : sunny
Departure Time : 06/12/2026 16:00
ASEC Technician Name : Samara Simha Reddy Kandi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
06/12/2026	1	29.6	92.1	2026-159	94.5	25.2	97.5	95	D6938	Pass
Location : Next to Suite 4, Elv/Depth :2.5 feet below finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
06/12/2026	2	30.3	91.1	2026-159	94.5	25.2	96.4	95	D6938	Pass
Location : Next to Suite 4, Elv/Depth :2.5 feet below finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										

Remark: Test performed in general accordance with signed referenced ASTM Method.

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 06/12/2026
Project No : 2026C142
Client Company : KFE
Arrival Time : 06/12/2026 14:00
Onsite Hours : 02:00

ASEC Report ID : 95287
Name of the Project : Bailey Station Way
Project Location : Sharpsburg
Weather : sunny
Departure Time : 06/12/2026 16:00
ASEC Technician Name : Samara Simha Reddy Kandi

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
05/19/2026	2026-155	103.1	19.1	Standard	Red, brown sandy silt
05/21/2026	2026-159	94.5	25.2	Standard	Red, brown sandy silt with clay
05/21/2026	2026-160	118.2	14.9	Standard	Red, brown silty sand