

Date : 07/16/2026
Project No : 2025C281
Client Company : SR Homes
Arrival Time : 07/16/2026 13:00
Onsite Hours : 04:00

ASEC Report ID : 96232
Name of the Project : Owen Mills - Owens Store Rd
Project Location : Canton
Weather : sunny
Departure Time : 07/16/2026 17:00
ASEC Technician Name : Samara Simha Reddy Kandi

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
07/16/2026	1	3.4	139.5	2026-G233	137.1	3.6	101.8	100	D6938	Pass
Location : Main road, 45' from curb end east side, 6'-6" to curb, Elv/Depth :at finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
07/16/2026	2	3.0	140.9	2026-G233	137.1	3.6	102.8	100	D6938	Pass
Location : 20' from curbline at entrance, Elv/Depth :at finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
07/16/2026	3	2.9	137.7	2026-G233	137.1	3.6	100.4	100	D6938	Pass
Location : 7' from curbline west side from entrance, Elv/Depth :at finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
07/16/2026	4	3.0	140.9	2026-G233	137.1	3.6	102.8	100	D6938	Pass
Location : 500' from entrance from catch basin close to Island, Elv/Depth :at finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
07/16/2026	5	2.8	141.7	2026-G233	137.1	3.6	100.5	100	D6938	Pass
Location : SE catch basin 30' from end, Elv/Depth :at finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
07/16/2026	6	3.1	142.1	2026-G233	137.1	3.6	100.5	100	D6938	Pass
Location : from catch basin 7' east side, Elv/Depth :at finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
07/16/2026	7	2.2	141.6	2026-G233	137.1	3.6	101.1	100	D6938	Pass
Location : from catch basin 500', Elv/Depth :at finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										
07/16/2026	8	2.4	142.4	2026-G233	137.1	3.6	101.5	100	D6938	Pass
Location : From corner of catch basin, 20' NE, Elv/Depth :at finished grade										
Comment :										
Tested By : Samara Simha Reddy Kandi Gauge Serial No. : 38069										

Remark: Test performed in general accordance with signed referenced ASTM Method.

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consulting LLC.

Date : 07/16/2026
Project No : 2025C281
Client Company : SR Homes
Arrival Time : 07/16/2026 13:00
Onsite Hours : 04:00

ASEC Report ID : 96232
Name of the Project : Owen Mills - Owens Store Rd
Project Location : Canton
Weather : sunny
Departure Time : 07/16/2026 17:00
ASEC Technician Name : Samara Simha Reddy Kandi

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
12/16/2025	2025-052 (off-site stockpile)	101.1	22.6	Standard	Brown Sandy SILT
01/09/2026	2026-002 (on-site cut)	108.9	15.8	Standard	Red micaceous Silty SAND
01/13/2026	2026-001 (on site cut)	99.1	20.1	Standard	Red fine to medium Silty SAND
07/15/2026	2026-G233	137.1	3.6	Standard	GAB