AS Engineering and Consulting LLC

# Density Test Report

Date : 08/14/2026
Project No : 2025C214
Client Company : Artisan
Arrival Time : 08/14/2026
Onsite Hours : N/A

ASEC Report ID : 96854
Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
Project Location : Dallas
Weather : sunny
Departure Time : 08/14/2026
ASEC Technician Name : Russell Hendrix

| Test Date | Test Number | Moisture Content (%) | Dry Density (pcf) | Proctor Number | Max. Dry Density (pcf) | Optimum Moisture (%) | Compaction (%) | Specified Compaction (%) | ASTM Test Method | Pass/Fail |
|---|---|---|---|---|---|---|---|---|---|---|
| 08/14/2026 | 1 | 18.5 | 101.7 | North Bridge mixture | 106.8 | 17.5 | 95.2 | 95 | D6938 | Pass |
| Location : West side of Bridge - North end, 10 feet from wall, Elv/Depth :3 feet below finished grade | | | | | | | | | | |
| Comment : | | | | | | | | | | |
| Tested By : Russell Hendrix | | | | | Gauge Serial No. : 92204 | | | | | |

**Remark:** Test performed in general accordance with signatured referenced ASTM Method.

Kenneth Mosman

**Kenneth Mosman**

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consultiing LLC.

AS Engineering and Consulting LLC

# Density Test Report

Date : 08/14/2026
Project No : 2025C214
Client Company : Artisan
Arrival Time : 08/14/2026
Onsite Hours : N/A

ASEC Report ID : 96854
Name of the Project : NW Unit 4 BRIDGE (Materials Testing)
Project Location : Dallas
Weather : sunny
Departure Time : 08/14/2026
ASEC Technician Name : Russell Hendrix

## PROCTOR DATA SUMMARY

| TEST DATE | PROCTOR ID | MAX DRY DENSITY (pcf) | OPTIMUM MOISTURE (%) | PROCTOR TYPE | SOIL DESCRIPTION |
|---|---|---|---|---|---|
| 07/28/2025 | 2025-031 SP | 101.0 | 20.7 | Standard | Tan, brown micaceous sandy SILT |
| 07/28/2025 | 2025-032 SP | 94.9 | 25.0 | Standard | Red micaceous sandy CLAY |
| 08/01/2025 | 2025-033 SP | 104.0 | 16.2 | Standard | Tan, brown micaceous sandy SILT |
| 08/14/2025 | 2025-035 SP | 107.8 | 13.0 | Standard | Red sandy SILT |
| 08/14/2025 | 2025-036 SP | 107.0 | 18.5 | Standard | Red micaceous sandy SILT |
| 01/30/2026 | Field proctor #6 | 98.0 | 17.2 | Standard | Multi-colored sandy SILT |
| 05/07/2026 | 2026-136 | 113.0 | 14.0 | Standard | Red brown silty sand |
| 05/19/2026 | North Bridge mixture | 106.8 | 17.5 | Standard | Red brown sandy silt with clay |