Daily Field Report

Date : 09/02/2026
Project No : 2021C060
Client Company : Pulte Group
Arrival Time : 09/02/2026 14:00
Onsite Hours : 02:00

ASEC Report ID : 97392
Name of the Project : Suncity - Peachtree
Project Location : Griffin, GA
Weather : sunny
Departure Time : 09/02/2026 16:00
ASEC Technician Name : Samara Simha Reddy Kandi

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

DCP testing was performed at Lot 19-18. The soil encountered consisted of red silty clayey sand.

DCP Test 1:
1 ft – 14 blows
Auger refusal encountered below 1 foot.

DCP Test 2:
1 ft – 15 blows
Auger refusal encountered below 1 foot.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.

Daily Field Report

Date : 09/02/2026
Project No : 2021C060
Client Company : Pulte Group
Arrival Time : 09/02/2026 14:00
Onsite Hours : 02:00

ASEC Report ID : 97392
Name of the Project : Suncity - Peachtree
Project Location : Griffin, GA
Weather : sunny
Departure Time : 09/02/2026 16:00
ASEC Technician Name : Samara Simha Reddy Kandi

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consultiing LLC.