Daily Field Report

Date : 09/02/2026
Project No : 2026C136
Client Company : SR Homes
Arrival Time : 09/02/2026 09:00
Onsite Hours : 02:00

ASEC Report ID : 97387
Name of the Project : Collett Farms Storm Line & Pavement
Project Location : Canton
Weather : sunny
Departure Time : 09/02/2026 11:00
ASEC Technician Name : Samara Simha Reddy Kandi

As requested, the site was visited by our AS Engineering and Consulting (ASEC) representative for the purpose of providing quality control inspection and testing services. Visual observation techniques were employed to verify compliance with project drawing/specifications, applicable codes, and materials submittals. The following observations were observed on site this day.

Roadway subgrade proof-rolling was performed by the contractor using a loaded dump truck at the following locations:

1. Entrance – Acceleration and Deceleration Lanes:
Proof-rolling was performed on the sub-grade within the acceleration and deceleration lane areas at the project entrance near East Cherokee Drive. No pumping, rutting, excessive deflection, or other signs of instability were observed during proof rolling. The sub-grade was considered acceptable for placement of aggregate base.

2. Curb Side:
Proof-rolling was performed on the subgrade along the curb-side area, including the areas near inlet DWCB-D4. No pumping, rutting, excessive deflection, or other signs of instability were observed. The proof-rolled sub-grade was considered acceptable for placement of aggregate base.

We appreciate the opportunity to be of service to you on this project. If you have any questions regarding this report, please feel free to contact us. We will be more than happy to discuss it with you.





Kenneth Mosman

Kenneth Mosman

AS Engineering and Consulting LLC

Daily Field Report

Date : 09/02/2026
Project No : 2026C136
Client Company : SR Homes
Arrival Time : 09/02/2026 09:00
Onsite Hours : 02:00

ASEC Report ID : 97387
Name of the Project : Collett Farms Storm Line & Pavement
Project Location : Canton
Weather : sunny
Departure Time : 09/02/2026 11:00
ASEC Technician Name : Samara Simha Reddy Kandi

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consultiing LLC.