AS Engineering and Consulting LLC

Density Test Report

Date : 09/28/2026
Project No : 2026C100
Client Company : Artisan
Arrival Time : 09/28/2026 07:30
Onsite Hours : 06:00

ASEC Report ID : 97890
Name of the Project : Naturewalk PHASE 3, UNIT 4 (formerly called PH 2 Extension) Lots
Project Location : Dallas
Weather : Sunny
Departure Time : 09/28/2026 13:30
ASEC Technician Name : Clyde Smith

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
09/28/2026	1	13.1	101.5	2025-033 SP	104.0	16.2	97.6	95	D6938	Pass
Location : Building lots at Unit 4, Phase 3, Elv/Depth :5 feet below finished grade Comment : Tested By : Clyde Smith Gauge Serial No. : 91643										
09/28/2026	2	13.9	101.2	2025-033 SP	104.0	16.2	97.3	95	D6938	Pass
Location : Building lots at Unit 4, Phase 3, Elv/Depth :5 feet below finished grade Comment : Tested By : Clyde Smith Gauge Serial No. : 91643										
09/28/2026	3	14.1	102.5	2025-033 SP	104.0	16.2	98.6	95	D6938	Pass
Location : Building lots at Unit 4, Phase 3, Elv/Depth :4.5 feet below finished grade Comment : Tested By : Clyde Smith Gauge Serial No. : 91643										
09/28/2026	4	12.8	105.7	2025-035 SP	107.8	13.0	98.1	95	D6938	Pass
Location : Building lots at Unit 4, Phase 3, Elv/Depth :4.5 feet below finished grade Comment : Tested By : Clyde Smith Gauge Serial No. : 91643										
09/28/2026	5	11.8	105.5	2025-035 SP	107.8	13.0	97.9	95	D6938	Pass
Location : Building lots at Unit 4, Phase 3, Elv/Depth :4 feet below finished grade Comment : Tested By : Clyde Smith Gauge Serial No. : 91643										
09/28/2026	6	14.2	102.8	2025-033 SP	104.0	16.2	98.8	98	D6938	Pass
Location : Building lots # 10 thru 15 at Seven Hills phase 13, Elv/Depth :at finished grade Comment : Tested By : Clyde Smith Gauge Serial No. : 91643										
09/28/2026	7	14.4	102.8	2025-033 SP	104.0	16.2	98.8	98	D6938	Pass
Location : Building lots # 10 thru 15 at Seven Hills phase 13, Elv/Depth :at finished grade Comment : Tested By : Clyde Smith Gauge Serial No. : 91643										
09/28/2026	8	12.1	106.8	2025-035 SP	107.8	13.0	99.1	98	D6938	Pass
Location : Building lots # 10 thru 15 at Seven Hills phase 13, Elv/Depth :at finished grade Comment : Tested By : Clyde Smith Gauge Serial No. : 91643										
09/28/2026	9	13.7	102.6	2025-033 SP	104.0	16.2	98.7	98	D6938	Pass

AS Engineering and Consulting LLC

Density Test Report

Date : 09/28/2026
Project No : 2026C100
Client Company : Artisan
Arrival Time : 09/28/2026 07:30
Onsite Hours : 06:00

ASEC Report ID : 97890
Name of the Project : Naturewalk PHASE 3, UNIT 4 (formerly called PH 2 Extension) Lots
Project Location : Dallas
Weather : Sunny
Departure Time : 09/28/2026 13:30
ASEC Technician Name : Clyde Smith

Test Date	Test Number	Moisture Content (%)	Dry Density (pcf)	Proctor Number	Max. Dry Density (pcf)	Optimum Moisture (%)	Compaction (%)	Specified Compaction (%)	ASTM Test Method	Pass/Fail
Location : Building lots # 10 thru 15 at Seven Hills phase 13, Elv/Depth :at finished grade Comment : Tested By : Clyde Smith Gauge Serial No. : 91643										
09/28/2026	10	22.4	91.7	2025-032 SP	94.9	25.0	96.6	95	D6938	Pass
Location : Building lots at Unit 4, Phase 3, Elv/Depth :4 feet below finished grade Comment : Tested By : Clyde Smith Gauge Serial No. :										
09/28/2026	11	22.7	92.0	2025-032 SP	94.9	25.0	96.9	95	D6938	Pass
Location : Building lots at Unit 4, Phase 3, Elv/Depth :4 feet below finished grade Comment : Tested By : Clyde Smith Gauge Serial No. : 91643										
09/28/2026	12	13.9	102.6	2025-033 SP	104.0	16.2	98.7	95	D6938	Pass
Location : Building lots at Unit 4, Phase 3, Elv/Depth :4 feet below finished grade Comment : Tested By : Clyde Smith Gauge Serial No. : 91643										

Remark: Test performed in general accordance with signatured referenced ASTM Method.

Kenneth Mosman

Kenneth Mosman

The results presented in this report relate only to the items tested. This report shall not be reproduced, except in full, without written approval from AS Engineering and Consultiing LLC.

Density Test Report

Date : 09/28/2026
Project No : 2026C100
Client Company : Artisan
Arrival Time : 09/28/2026 07:30
Onsite Hours : 06:00

ASEC Report ID : 97890
Name of the Project : Naturewalk PHASE 3, UNIT 4 (formerly called PH 2 Extension) Lots
Project Location : Dallas
Weather : Sunny
Departure Time : 09/28/2026 13:30
ASEC Technician Name : Clyde Smith

PROCTOR DATA SUMMARY

TEST DATE	PROCTOR ID	MAX DRY DENSITY (pcf)	OPTIMUM MOISTURE (%)	PROCTOR TYPE	SOIL DESCRIPTION
07/28/2025	2025-031 SP	101.0	20.7	Standard	Tan, brown micaceous sandy SILT
07/28/2025	2025-032 SP	94.9	25.0	Standard	Red micaceous sandy CLAY
08/01/2025	2025-033 SP	104.0	16.2	Standard	Tan, brown micaceous sandy SILT
08/14/2025	2025-035 SP	107.8	13.0	Standard	Red sandy SILT
08/14/2025	2025-036 SP	107.0	18.5	Standard	Red micaceous sandy SILT
01/30/2026	Field proctor #6	98.0	17.2	Standard	Multi-colored sandy SILT